

**Awareness Program for Operation Staff
Kotmale Power Station**


Water Management

By:

**Eng., Nizam Salih
Electrical Engineer (Operations)**

December, 2009

Water Management



Storage / MCM	
703 m	174
665 m	20

1MCM = $1 \times 10^6 \text{ m}^3$

Spill Level	=	703 m (Above MSL)
Minimum Operating Level	=	665 m (Above MSL)
*Tailrace Level	=	476 m (Above MSL)

Maximum Head = 227 m

Minimum Head = 189 m

- Refer to the diagram and commissioning reports for a better understanding of the Tailrace Level determination.

Water Management

Power o/p from Generator

Rule of Thumb

$$P = 7HQ \text{ (KW)}$$

Where

H = net head (m)

Q = flow rate (m³/s)

Correct equation

$$P = \rho gHQ\eta_t\eta_G \text{ (W)}$$

Where

ρ = density of water (1000 kg/m³)

g = gravitational constant (9.81 m/s²)

H = net head (m)

Q = flow rate (m³/s)

η_t = Turbine efficiency

η_G = Generator efficiency

Water Management


Gross Head

The difference between headwater elevation and tailwater elevation.

Net Head

The effective head on the turbine and is equal to the gross head minus the hydraulic losses before entrance to the turbine and outlet losses.

Schematic view of the Energy Losses in an hydro power scheme



BOVING
KMW
turbin ab

COMMISSIONING PROGRAM
RECORD SHEET
OBJECT: See below

KOTMALE

Unit No. 3

Date

Sheet 5

Appr.
Sign.

PRESSURE- AND WINTER KENNEDY TAPS IN SPIRAL CASE.

TEST NO	1	2	3	4	5		
DATE	17-2-88	21-2-88	12-3-88	17-3-88	17-3-88		
H.W.L	66.42	680.89	674.69	674.70	674.66	686.42	H.W.L
T.D.C	477.74	478.05	478.30	478.0	478.30	477.74	T.D.C
DIS HEAD LOSS	0.91	1.18	0.16	0.42	1.20	208.68	0/2 test
VEL HEAD AT INLET	-	5.14	0.65	2.22	5.38	207.77	1/2 test
NET HEAD	70.77	70.66	70.73	70.28	70.05		
M.W (inlet)	60	65	20	40	62		
M.W (MW-HR)	59.88	64.06	20.45	39.3	62.9		
GEN η	0.78	0.72	0.97	0.76	0.78		
M.W (pressure)	61.1	65.4	21.1	40.3	64.2		
NET TURBINE η	0.45	0.44	0.8	0.91	0.835		
Q (acc to η)	31.75	35.2	13.7	23.0	35.9		
Q (acc to $\frac{1}{25}$)	-	34.8	12.4	22.9	35.6		
Q (INDICATED)	32	36.5	9.8	22.5	36.5		

Harsh Bhowani
Contractor

P. S. Roy 18.2.88
Engineer

BOVING
KMW
turbin ab

COMMISSIONING PROGRAM
RECORD SHEET
OBJECT: ACCEPTANCE TEST

KOTHALE

Unit No. 3

Date

Sheet 14

Appr.
Sign.

a Capacity test

TEST NO	1	2	3		
DATE	16.2.88	20.2.88	17.3.88		
H/WL	686.69	680.89	674.66		686.69 498.20
T/WL	478.20	478.05	478.30		686.69 - 1.19
U/S HEAD LOSS	1.19	1.18	1.30		207.7
NET HEAD	201.3	201.66	195.06		207.7 Gross = 207.7 net head = 201.3
ACTUATOR POS %	77.5	79	85		
SVO (avg) mm	88	89.5	95		
MAX STABLE MLD (s) (NOISE)	66	65	63		
MAX STABLE MLD (s) (MIN NOISE)	65.7	64.05	62.9		
GENERATOR η	0.98	0.98	0.98		
MAX STABLE MLD (s)	67.0	65.4	64.2		

[Signature]
Contractor

[Signature] 23.3.88
Engineer

BOVING
KMW
turbin ab

COMMISSIONING PROGRAM
RECORD SHEET
OBJECT: ACCEPTANCE TEST

KOTMALE

Unit No. 3

Date

Sheet 4

Appr.
Sign.

a Capacity test

TEST NO	1	2	3		
DATE	16.2.88	29.2.88	17.3.88		
HWL	686.69	680.89	674.66		
TWL	478.20	478.05	478.30		
U/S HEAD LOSS	1.19	1.18	1.30		
NET HEAD	207.3	201.66	195.06		
ACTUATOR POS %	77.5	79	85		
GVO (av) mm	88	89.5	95		
MAX STABLE MW (6) (INDIC)	66	65	63		
MAX STABLE MW (6) (MW-HE)	65.7	64.06	62.9		
GENERATOR η	0.98	0.98	0.98		
MAX STABLE MW (7)	67.0	65.4	64.2		

686.69
478.20

Fail
Pass

208.49
- 1.19

Fail

207.3

Pass

Fail = still
not hand-cycled
head

BOVING
KMW
turbin ab

COMMISSIONING PROGRAM
RECORD SHEET
OBJECT: ACCEPTANCE TEST

KOTMALE

Unit No. 3

Date

Sheet 14

Appr.
Sign.


a Capacity test

TEST NO.	1	2	3		
DATE	16.2.88	29.2.88	17.3.88		
HWL	686.69	680.89	674.66		686.69 678.20
TWL	478.20	478.05	478.30		218.49 - 1.19
U/S HEAD LOSS	1.19	1.18	1.30		207.3
NET HEAD	207.3	201.66	195.06		Crust = shaft net head w/o pen head
ACTUATOR POS %	77.5	79	85		
GVO (a ₀) mm	88	89.5	95		
MAX STABLE mω (g) (INDIC)	66	65	63		
MAX STABLE mω (g) (MW-He)	65.7	64.06	62.9		
GENERATOR η	0.98	0.98	0.98		
MAX STABLE mω (r)	67.0	65.4	64.2		


[Signature]

[Signature] 23.3.88

View of a Francis Turbine



Guide vane functioning principle




Draft Tube


The draft tube of a reaction turbine aims to recover the kinetic energy still remaining in the water leaving the runner.

As this energy is proportional to the square of the velocity one of the draft tube objectives is to reduce the turbine outlet velocity. $(V^2/2g)$


An efficient draft tube would have a conical section but the angle cannot be too large, otherwise flow separation will occur. The optimum angle is 7° but to reduce the draft tube length, and therefore its cost, sometimes angles are increased up to 15°



Draft Tube



Flow duration curve



1
3
5

...

Firm energy

Firm energy is defined as the power that can be delivered by a specific plant during a certain period of the day with at least 90 –95% certainty. A run-of-river scheme has a low firm energy capacity. A hydropower plant with storage does, however, have considerable capacity for firm energy.

If the hydropower scheme is to be connected to an electrical network that includes several types of power and where the hydropower installations are geographically distributed, as is the case in Europe, the firm power capacity of singular plants may, not be important.


Kotmale Firm Energy ???

310 GWh


The efficiency guaranteed by turbine manufacturers is that which may be verified in accordance with the "International Code for the field acceptance tests of hydraulic turbines" (publication IEC 60041) or, if applied, in accordance with the "International Code for model acceptance tests" (publication IEC 60193).

It is defined as the ratio of power supplied by the turbine (mechanical power transmitted by the turbine shaft) to the hydraulic power.


Kotmale Turbine Name Plate Data




LONGITUDINAL SECTION OF THE WATER CONDUCTING SYSTEM




CROSS SECTION THROUGH MACHINE AND SURGE CHAMBER




LOCATION PLAN



LONGITUDINAL SECTION ALONG LOW PRESSURE AND TAILRACE TUNNELS



TYPICAL CROSS SECTION OF DAM



END